

CERTIFICATE OF COMPLIANCE

Certificate Number 20130820-E226209
Report Reference E226209-20130817
Issue Date 2013-AUGUST-20

Issued to: MIGATRON CORP
935 DIECKMAN ST
WOODSTOCK IL 60098

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS
Refer next page for Model

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 913 - Intrinsically Safe Apparatus and Associated Apparatus for Use
in Class I, II, and III, Division 1, Hazardous (Classified)
Locations.,CAN/CSA C22.2 No. 157-92 - Intrinsically Safe and Non-
incendive Equipment for Use in Hazardous Locations.,UL 61010-1 -
Electrical Equipment for Measurement, Control, and Laboratory - Part
1: General Requirements.and CSA C22.2 No. 61010-1 - Safety
Requirements for Electrical Equipment for Measurement, Control, and
Laboratory Use - Pt. 1, General Requirements

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as
being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US
and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and
"US" identifiers: 251658240^c^{us} the word "LISTED"; a control number (may be alphanumeric)
assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL
Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130820-E226209
Report Reference E226209-20130817
Issue Date 2013-AUGUST-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Associated Apparatus for use in Unclassified Locations.

USL, CNL Model ZSB-409A zener diode barrier, providing intrinsically safe outputs for use in Class I, Div. 1, Groups A, B, C and D; Class II, Div. 1, Groups E, F and G; and Class III, Div. 1 hazardous locations when installed per Control Drawing No. Ex05121109.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

